



VALLEY UNDERLAYMENTS

OVERLAPPING UNDERLAYMENT

MC-03A



Note:
The underlayment options shown on MC-03A or MC-03B are viable options for any valley metal configuration.



Notes:

1. One layer of No. 30 asphalt-saturated felt complying with ASTM D-226 Type II (ASTM D4869 TYPE IV) or approved equal is required as minimum underlayment on all tile roof applications. Other underlayments as approved by local building officials shall be allowed.

Drawing shown depicts the application of all tile profiles. Unless otherwise noted it would apply to either concrete or clay tiles.