

ICC-ES Evaluation Report**ESR-1900 CBC and CRC Supplement**

Issued June 1, 2011

This report is subject to renewal on March 1, 2012.www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

DIVISION: 07 00 00—THERMAL AND MOISTURE PROTECTION
Section: 07 32 16—Concrete Roof Tiles**REPORT HOLDER:****EAGLE ROOFING PRODUCTS, A DIVISION OF BURLINGAME INDUSTRIES, INC.**
3546 NORTH RIVERSIDE AVENUE
RIALTO, CALIFORNIA 92377
(909) 822-6000
www.eagleroofing.com**EVALUATION SUBJECT:****EAGLE® AND EAGLELITE® INTERLOCKING CONCRETE ROOFING TILES: CAPISTRANO, MALIBU, BEL AIR, BEL AIR ESTATE, BEL AIR DOUBLE EAGLE, PONDEROSA, PONDEROSA ESTATE, PONDEROSA DOUBLE EAGLE AND PONDEROSA GOLDEN EAGLE****1.0 EVALUATION SCOPE****Compliance with the following codes:**2010 *California Building Code* (CBC)
2010 *California Residential Code* (CRC)**Properties evaluated:**

- Fire classification
- Weather resistance
- Wind-uplift resistance

2.0 California Building Code

The Eagle® and EagleLite® Interlocking Concrete Roof Tiles described in the master report, ESR-1900, may be used where a Class A roof covering complying with Section 1505.1.1, a Class B roof covering complying with Section 1505.1.2, or a Class C roof covering complying with Section 1505.1.3 of the CBC is required, provided installation is in accordance with the master report and the additional requirements of Sections 1507.3.10 and 1511 of the CBC.

The roof tiles may be used in the construction of new buildings located in a Fire Hazard Severity Zone within State Responsibility Areas or any Wildland-Urban Interface Fire Area, provided installation is also in accordance with the master report and the additional requirements of Sections 701A.3 and 705A of the CBC.

3.0 California Residential Code

The Eagle[®] and EagleLite[®] Interlocking Concrete Roof Tiles described in the master report, ESR-1900, may be used where a Class A roof covering complying with Section R902.1.1, a Class B roof covering complying with Section R902.1.2, or a Class C roof covering complying with Section R902.1.3 of the CRC is required, provided installation is in accordance with the master report and the additional requirements of Section R905.3 of the CRC.

The roof tiles may be used in the construction of new buildings located in any Wildland-Urban Interface Fire Area, provided installation is also in accordance with the master report and the additional requirements of Sections R327.1.3.1 and R327.5 of the CRC.

The products recognized in this supplement have not been evaluated for compliance with the *International Wildland-Urban Interface Code*[®].

This supplement expires concurrently with the master report reissued on March 1, 2011.